



EBS MANNHEIM –

WASTEWATER DEPARTMENT CITY OF MANNHEIM

TABLE OF CONTENTS

Key dates

Locations und employees

Organisation

Distribution of staff

Wastewater charges and expenses

Expense distribution

Sewage disposal

Age structure of sewers

Sewerage system inspection

Sewer database

Renovation and construction of sewer

Wastewater treatment plant

Environmental performance

Material balance

Activated carbon plant

Renewable energies



KEY DATES

Foundation	1997-01-01
Employees	260
Fixed assets	348 Mio. €
Investment	11,7 Mio. €

Quality and Environmental Management System Certified according to EN ISO 9001 / EN ISO 14001 since 2003-01



KEY DATES

Sewage treatment plant	725.000 population equivalents (design size) approx. 89.000 m ³ flow of wastewater per day
Sewage system	838 km (without house connection sewers)combined discharge39 pumping stations32 lifting equipments
Rain-/storm water treatment	8 overflow basins 8 storm water retention tanks 12 storage capacities of sewer 2 rainwater infiltration facilities
Retention volume in total	approx. 170.000 m ³



LOCATIONS AND EMPLOYEES


Wastewater treatment

161 employees

Karl-Imhoff-Straße 50 68307 Mannheim


Sewerage disposal and administration

99 employees Käfertaler Straße 265 68167 Mannheim






ORGANISATION





DISTRIBUTION OF STAFF



WASTEWATER CHARGES AND EXPENSES


Sewage fees Per cubic metre of delivered drinking water	1,68 € (since 2021-
Rain water fees Per square metre and year of drained surface	0,80 € (since 2021-
Income (Wastewater Charges)	59,7 Mio. €
Material costs	17,4 Mio. €
Personnel costs	17,4 Mio. €
Depreciations	15,0 Mio. €
Financial result	6,4 Mio. €

1,68 € (since 2021-01-01, before 1,61 €)

0,80 € (since 2021-01-01, before 0,83 €)



EXPENSE DISTRIBUTION





SEWERAGE DISPOSAL


Sewerage system length 838 km under the responsibility of EBS Mannheim

Year of sewerage system construction Since 1876

Sewer section 250 – 5.200 mm

Canalized area approx. 7.100 ha


Connection to sewerage system 99,9 %







AGE STRUCTURE OF SEWERS





SEWERAGE SYSTEM INSPECTON

Examination in total	100,0 %
Analog based on walking through	5,6 %
Digital based on TV examination (since 1986)	94,4 %








SEWER DATABASE

Administration of the sewer inventory data for the whole urban area

- Survey data (channel geometry and topography)
- Data from the TV-Inspection Gathering of the sewer conditions
- Gathering of the house connections (noozles)
- Special buildings
- Hydraulic performance of the sewer system
- Indirect discharge data
- Data of the plants





RENOVATION AND CONSTRUCTION OF SEWER

Length in total of

repaired sewer:	approx. 5,8 km
renovated sewer:	approx. 22,6 km
renewed sewer:	approx. 0,5 km





WASTEWATER TREATMENT PLANT

Operation

- 1973 Wastewater treatment plant
- 1986 Filtration
- 1999 New biological plant
- 2016 Fourth treatment stage (removal of pharmaceuticals, etc.)

Flow of wastewater at dry weather Conditions per day: approx. 89.000 m³

725.000 population equivalents (design size), approx. 50% from the industry





ENVIROMENTAL PERFORMANCE


		Raw waste water mg/l	Treated waste water mg/l	Effiency level %
Chemical oxygen demand	COD	942	17	98,2
Organic carbon in total	тос	322	6,05	98,1
Nitrogen in total	N _{tot}	75,4	5,00	93,4
Phosphor in total	P _{tot}	12,43	0,10	99,2





MATERIAL BALANCE

Raw water: approx. 32,6 Mio. m³ flow of wastewater per year (approx. 89.000 m³ flow of wastewater per day)




ACTIVATED CARBON PLANT

Micropollutants are being removed from wastewater by dosing powdered activated carbon.

Micropollutants consist of residues from pharmaceuticals, X-ray contrast media, chemicals from industries and households, aromatic substances, etc.

5 parallel tanks

Maximum flow 2000 l/s, 90% of the annual wastewater flow are being treated





RENEWABLE ENERGIES

Sludge treatment at the digesters

since 1973 Digesters

since 1996 Drying



- To generate electricity and heat :
- \rightarrow Co-generation plant

To generate heat :

 \rightarrow Sludge drying

Photovoltaic and Waterpower

since 2007



To generate electricity:

 \rightarrow Solarpanel on top of the filtration plant

 \rightarrow Water wheel at the outlet to the Rhine

Supply of Co-Substrates

since 2012



To generate additional gas:

 \rightarrow Co-Substrates will be supplying at the digesters in addition



CONTACT: STADTENTWÄSSERUNG MANNHEIM KÄFERTALER STRASSE 265 68167 MANNHEIM PHONE: 0621 293-5210 FAX: 0621 293-5211

MAIL: STADTENTWAESSERUNG@MANNHEIM.DE



